


管理値超過時の記録シート【騒音】

2019年1月15日


時間	L _{A5,1h} (dB)	管理値			時間	L _{A5,1h} (dB)	管理値			時間	L _{A5,1h} (dB)	管理値		
		1次	2次	自主			1次	2次	自主			1次	2次	自主
		77dB	80dB	85dB			77dB	80dB	85dB			77dB	80dB	85dB
11:40	76.4									14:21	78.7	○		
11:41	76.7									14:22	78.8	○		
11:42	76.7									14:23	78.9	○		
11:43	76.9				13:30	74.2				14:24	79.1	○		
11:44	77.0	○			13:31	74.3				14:25	79.2	○		
11:45	77.0	○			13:32	74.7				14:26	79.1	○		
11:46	77.1	○			13:33	74.8				14:27	79.1	○		
11:47	77.2	○			13:34	75.5				14:28	78.9	○		
11:48	77.2	○			13:35	76.2				14:29	78.7	○		
11:49	77.1	○			13:36	77.4	○			14:30	78.7	○		
11:50	77.1	○			13:37	77.6	○			14:31	78.7	○		
11:51	77.1	○			13:38	77.6	○			14:32	78.7	○		
11:52	77.2	○			13:39	77.9	○			14:33	78.7	○		
11:53	77.2	○			13:40	77.9	○			14:34	78.1	○		
11:54	77.2	○			13:41	77.9	○			14:35	77.3	○		
11:55	77.2	○			13:42	78.0	○			14:36	76.5			
11:56	77.2	○			13:43	78.0	○			14:37	76.2			
11:57	77.2	○			13:44	78.3	○			14:38	76.3			
11:58	77.3	○			13:45	78.3	○			14:39	76.1			
11:59	77.3	○			13:46	78.3	○			14:40	75.9			
12:00	77.3	○			13:47	78.3	○			14:41	75.9			
12:01	77.3	○			13:48	78.3	○			14:42	75.9			
12:02	77.3	○			13:49	78.3	○			14:43	75.8			
12:03	77.3	○			13:50	78.3	○			14:44	75.5			
12:04	77.3	○			13:51	78.3	○			14:45	75.5			
12:05	77.3	○			13:52	78.3	○			14:46	75.5			
12:06	77.3	○			13:53	78.6	○			14:47	75.5			
12:07	77.3	○			13:54	78.6	○			14:48	75.5			
12:08	77.3	○			13:55	78.6	○			14:49	75.5			
12:09	77.3	○			13:56	78.6	○			14:50	75.5			
12:10	77.3	○			13:57	78.6	○			14:51	75.6			
12:11	77.3	○			13:58	78.6	○			14:52	75.5			
12:12	77.3	○			13:59	78.6	○			14:53	75.1			
12:13	77.3	○			14:00	78.6	○			14:54	75.1			
12:14	77.3	○			14:01	78.6	○			14:55	75.1			
12:15	77.3	○			14:02	78.6	○			14:56	75.1			
12:16	77.3	○			14:03	78.6	○			14:57	75.2			
12:17	77.3	○			14:04	78.6	○			14:58	75.2			
12:18	77.2	○			14:05	78.6	○			14:59	75.2			
12:19	77.2	○			14:06	78.6	○			15:00	75.3			
12:20	77.2	○			14:07	78.6	○							
12:21	77.2	○			14:08	78.6	○							
12:22	77.2	○			14:09	78.6	○							
12:23	76.9				14:10	78.6	○							
12:24	76.6				14:11	78.6	○							
12:25	76.2				14:12	78.7	○							
12:26	76.1				14:13	78.8	○							
12:27	76.1				14:14	78.8	○							
12:28	76.1				14:15	78.8	○							
12:29	76.1				14:16	78.8	○							
12:30	76.1				14:17	78.8	○							
12:31	75.8				14:18	78.7	○							
12:32	75.6				14:19	78.7	○							
12:33	75.6				14:20	78.7	○							



管理値超過地点	イーストスクエア27 2F
管理値超過項目	騒音
工事による超過か	×
基本対策は実施されているか	—
測定機器は正常に動作しているか	○

※自主管理値超過時は、工事を中断し
大阪市北部方面管理事務所へ連絡を行うこと。

TEL : 06-6462-1460 (平日)
06-6462-1434 (代表)



管理値超過時状況	他業者がイーストスクエア27号の立体駐車場を解体し、平面駐車場とする工事の準備工を実施していた。当該作業の内、単管打ち込み作業が騒音の発生源と思われる。
対策内容	管理値の超過は本工事によるものではないため、対策は実施していない。

その他・備考